



INFORMATIONAL BULLETIN

Bulletin No. 235

Page 1 of 3

Effective: 5/13/93

Approved: *[Signature]*

TEMPORARY POWER REQUIREMENTS FOR RESIDENTIAL CONSTRUCTION

The following requirements are based on the 1990 National Electrical Code and the So. Calif. Edison Co. Service requirements.

New residential construction shall have a temporary power service as described in "A" below. The Edison Co. will assist the owner or contractor in the location of the service.

On residential remodel, rebuild, or large additions to the home, the following criteria shall govern whether or not the existing service can supply both the home and the construction needs.

If the addition, remodel or rebuild warrants the occupants to move out while the work is being done, the owner and or contractor shall establish a temporary service in one of the following ways:

- A. A standard temporary power pole with the service on it.
- B. A plug-in temporary service adapter (piggy-back).

The above methods are shown as "example A" and example B".

If the work does not require the occupants to vacant the home, the existing service usually will be sufficient for the continued operation of the home and the construction power needs.