

## WATER CONSERVING PLUMBING **FIXTURE CERTIFICATION**

This certification may be used in lieu of verifying inspection as provided by Building and Safety Information Bulletin Number 321.

PERMIT NUMBER
LICENSE CLASS AND NUMBER
LICENSE CLASS AND NOMBER

I, the undersigned, hereby certify that I am the authorized contractor for the above referenced permit (Note: this would include an owner-builder). The following is a strict accounting of all toilets, shower heads, lavatory faucets, kitchen faucets and other faucets and their respective compliance circumstances per the Fixture Compliance Rates or Volumes table below.

## **FIXTURE COMPLIANCE RATES OR VOLUMES**

FIXTURE	NEW RATE OR VOLUME	EXISTING COMPLIANT RATE OR VOLUME	
Toilet	1.28 gal/flush	1.6 gal/flush	
Shower Head	2 gal/minute @ 80 psi	2.5 gal/minute	
Lavatory or Other Faucet	1.5 gal/minute max. @ 60 psi 0.8 gal/minute min. @ 20 psi	2.2 gal/minute	
Kitchen Faucet	1.8 gal/minute @ 60 psi*	2.2 gal/minute	
*NOTE: A new kitchen faucet may have a setting allowing for up to 2.2 gal/minute, however, the default must go to 1.8 gal/minute or less.			
CHECK AS APPROPRIATE TO INDICATE RATE OR VOLUME COMPLIANCE PER THE TABLE ABOVE, OR INDICATE N/A.			
BATHROOM 1			
TOILET NEW EXISTING		N/A SHOWER HEAD NEW EXISTING N/A	
BATHROOM 2 N/A			
TOILET NEW EXISTING LAV	ATORY NEW EXISTING	SHOWER HEAD NEW EXISTING N/A	
BATHROOM 3 N/A			
TOILET NEW EXISTING LAV	ATORY NEW EXISTING	SHOWER HEAD NEW EXISTING N/A	
BATHROOM 4 N/A			
TOILET NEW EXISTING	ATORY NEW EXISTING	SHOWER HEAD NEW EXISTING N/A	
KITCHEN FAUCET			
OTHER FAUCET(S)			
NEW EXISTING N/A SPE	CIFY:		
REMAINDER OF FIXTURES LISTED ON ATTACHED LIST			

YES N/A